



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems (see attached listing)

Prepared for:

Surya Global Steel Tubes Ltd
Survey No. 188, Anjar Mundra
Highway, Village - Buvad, Dist -
Kutch, P.C. 370130,
India

Manufactured by:

Surya Roshni Ltd
Survey No. 188, Anjar Mundra
Highway, Village - Buvad, Taluka-Anjar,
Dist - Kutch, Gujarat P.C. 370110,
India

FM Approvals Class: 1630

Approval Identification: 0003047635
Superseded by: RR212866

Date Approved: May 15, 2013
Date Approved: February 15, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA





Certificate of Compliance

Schedule 40-Normal connections are threaded, welded, rolled or cut groove or plain end

Schedule 40 a,b,c,d,e

a -FM Approved for use with FM Approved pipe couplings on rolled or cut grooves.

b -FM Approved for use with FM Approved pipe fittings when threaded.

c -FM Approved for use in welded systems when supplied with standard bevel on both ends.

d -When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems.

e -Any FM Approved pipe coupling or fitting suitable for use with Schedule 40 pipe may be used with this product at the lower rated pressure of the pipe or the fitting.



Member of the FM Global Group