

# Certificate of Compliance

Certificate Number **20100301 – EX15061**  
Report Reference **EX15061, 2006 September 21**  
Issue Date **2010 March 01**

Page 1 of 2



*Issued to:* **SURYA ROSHINI LTD**

**PRAKASH NAGAR, BAHADURGARH  
JHAJJAR, HR 124507 INDIA**


*This is to certify that  
representative samples of* **Metallic Sprinkler Pipe**  
**Refer to Addendum page**

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **The basic standard used to investigate products in this category is UL 852,  
"Metallic Sprinkler Pipe for Fire Protection Service."**

*Additional Information:* **See UL On-Line Certification Directory at [www.UL.com](http://www.UL.com) for additional  
Information.**

**Only those products bearing the UL Recognized Component Mark should be considered as being covered by UL's  
Recognition and Follow-Up Service.**

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

**Look for the UL Recognized Component Mark on the product**

Issued by: *Vidya Bhat*  
**Vidya.Bhat, Customer Service Professional**

**UL India Pvt. Ltd**

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.  
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd

Reviewed by: *William R Carney*  
**William R Carney, Director of the North American  
Certification Program.  
UL Inc. Division Office**

# Certificate of Compliance

Certificate Number **20100301 – EX15061**  
Report Reference **EX15061, 2006 September 21**  
Issue Date **2010 March 01**

Page 2 of 2



**Underwriters  
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Schedule 40 (black or galvanized) steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, and 12 in. sizes.

Schedule 30 (black or galvanized) steel pipe in the 14 and 16 in. sizes.

Schedule 20 (black or galvanized) steel pipe in the 10 and 12 in. sizes.

Schedule 10 (black or galvanized) steel pipe in the 14 and 16 in. sizes.

Issued by: *Vidya Bhat*  
**Vidya.Bhat, Customer Service Professional**

**UL India Pvt. Ltd**

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.  
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd

Reviewed by: *William R Carney*  
**William R Carney, Director of the North American  
Certification Program.  
UL Inc. Division Office**